



Address

Harregatplein 15

3214 VP Zuidland

Telephone

+31 (0) 181 45 21 20

E-mail

sales@indexelektro.nl

EU Declaration of Conformity
in accordance with
ATEX Directive 2014/34/EU



Manufacturer	Index Elektro BV	
Address	Harregatplein 15 3214 VP Zuidland the Netherlands	
Product Name	Control and Distribution Boxes	
Type	INDEX.E.XX.xxxx	
ATEX Mark	 II 2 G D Ex eb ... IIB/IIC T6...T4 Gb Ex tb... IIIB/IIIC T80°C ... T130°C Db Ta = -20°C/-40°C ≤ Ta ≤ +40°C/+55°C+80°C Possible additional types of protection: 'da/db', 'ma/mb', 'ia/ib' op is q (Refer to description in the certificate for full markings)	
Notified Body	CML B.V., Koopvaardijweg 32, Oosterhout, 4906 CV, The Netherlands	
Certificate no.	CML 18ATEX3276X	Notified Body no. 2776
Quality Assurance	CML B.V., Koopvaardijweg 32, Oosterhout, 4906 CV, The Netherlands	
Notified Body no.	2776	
Applicable Standards	EN 60079-0: 2012 + A11:2013 EN 60079-1: 2014 EN 60079-5: 2015 EN 60079-7: 2015	EN 60079-11: 2012 EN 60079-18: 2015 EN 60079-28: 2015 EN 60079-31: 2014
Declaration	The undersigned, representing the manufacturer, herewith declares that the object of the declaration described above is in conformity with the relevant Union harmonisation legislation Directive 2014/34/EU (from April 20th, 2016), when installed and maintained in accordance with the 'Safety and Maintenance Instruction'. GAP analysis has been done. The equipment is compliant with the latest edition of the Standards.	
Name	Ron den Hartigh	
Position	Authorized representative for ATEX	
Signature		
Date	27-2-2024	